

Guide Specification

Gypsum Plaster: California One-Kote, White Kote & Fenestra Old World Finish.

GUIDE SPECIFICATION SECTION 092613



GYPSUM PLASTER.

CALIFORNIA ONE-KOTE / WHITE KOTE / FENESTRA OLD WORLD FINISH.

This guide specification prepared by Sacramento Stucco is available in printed and electronic form as an aid to specifiers in preparing written construction documents for the application of WBP Gypsum Plaster products as a base coat and/or finish coat for interior plaster systems. Codes and requirements may have changed from the published date of this specification. Check with manufacturer for required updates.

Modify or add items as necessary. Delete items that are not applicable. Brackets (_____) reflect a choice to be made regarding inclusion or exclusion of a particular item or statement. *Italic sentences give special instructions.*

PART I – GENERAL

1.1 SCOPE:

- A. This specification describes the minimum requirements for the application of WBP Gypsum Plaster Base.
 1. Regular
 2. Fire-Rated
- B. WBP Gypsum Interior Plaster Finish

1.2 PERFORMANCE CRITERIA:

(Note: INCLUDE Fire-Resistance Rating statement when gypsum veneer plaster base is to be a component of a rated assembly)

A. Wall Assembly Fire-Resistance Rating: [Non-rated] [1-Hour] [1-1/2-Hour] [2-Hour] [3-Hour] [4-Hour]

1.3 QUALITY ASSURANCE:

- A. Manufacturers: Sacramento Stucco, Western Stucco, Rio Grande Stucco and Western Blended Products Approved Manufacturers.
 B. Contractor shall provide trained personnel gualified to install gypsum plaster and finishes per the scope of work described in this
- specification.
- 1.4 DELIVERY, STORAGE AND HANDLING:
 - A. Deliver, store, handle, and protect products for use on the project.
 - B. Deliver product to job site:
 - 1. Without exposure to weather or other forms of moisture.
 - 2. In manufacturer's unopened container, packages or bundles; clearly identified.
 - C. Store in dry, ventilated space off of the ground.
 - D. Protect materials from soiling, rusting and damage.

1.5 SITE CONDITIONS:

A. Contractor shall have reasonable and safe access to the jobsite for delivery, staging, storing, mixing and application of materials required for the described scope of work.

1.6 ENVIRONMENTAL CONDITIONS:

- A. Cold Weather Requirements: Provide heat and protection, temporary or permanent, as required to protect from freezing during and at least 24 hours after application or longer. When heaters are used, distribute heat uniformly.
- B. Warm Weather Requirements: Protect against uneven and excessive evaporation and from strong flows of dry air, both natural and artificial. Provide suitable coverings, barriers to deflect sunlight and wind, or combinations of these as required.

WBP Specifications

- C. Application Requirements: Apply when substrate and ambient air temperature are 40 degrees F and rising. Do not apply in temperatures over 95°.
- D. Protection: Protect existing surfaces prior to plastering by covering with suitable drop cloths.

1.7 SEQUENCING:

- A. The General Contractor shall coordinate communications between the trades and scheduling of the work prior to project commencement and while the work is in progress.
- B. Consult other trades in advance and make provisions for their work to avoid cutting and patching.
- C. Applicator of the Gypsum Plaster System shall schedule all inspections required by local authorities or product manufacturers, at each required stage, before continuing with the next stage of the system.

PART II – PRODUCTS

2.1 MANUFACTURERS:

- A. Sacramento Stucco Company, West Sacramento, CA.
- B. Western Stucco Company, Glendale, AZ.
- C. Rio Grande Stucco Company, El Paso, TX

2.2 PRODUCTS:

A.

- A. California One-Kote (GYPSUM BASECOAT REPAIR & FINISH COAT)
- B. White Kote (GYPSUM FINISH COAT)
- C. Fenestra Old World Finish (GYPSUM FINISH COAT)

2.3 GYPSUM BASE COAT:

- Basis of Design: California One-Kote
 - 1. Substrate Physical Characteristics
 - a. Drywall [Level 3]
 - b. Larsen's Plaster-Weld (non-diluted) bonder applied over substrate.
 - c. Overall Thickness: [Up to 3/4 inch Basecoat Repair]
 - d. Panel complies with requirements of ASTM C 1396 Standard Specification for Gypsum Board

2.4 FIRE-RESISTANCE RATED GYPSUM PLASTER BASE:

- A. Basis of Design: California One-Kote
 - 1. Type X Panel Physical Characteristics
 - a. Drywall [Level 3]
 - b. Larsen's Plaster-Weld (non-diluted) bonder applied over substrate.
 - c. Overall Thickness: [Up to 3/4 inch Basecoat Repair]
 - d. Panel complies with requirements of ASTM C 1396 Standard Specification for Gypsum Board

B. Basis of Design: California One-Kote

- 1. Type C Panel Physical Characteristics
 - a. Drywall [Level 3]
- b. Larsen's Plaster-Weld (non-diluted) bonder applied over substrate.
- c. Overall Thickness: [Up to 3/4 inch Basecoat Repair]
- d. Panel complies with requirements of ASTM C 1396 Standard Specification for Gypsum Board

2.5 GYPSUM PLASTER BASE:

- A. Basis of Design: California One-Kote
 - 1. Physical Characteristics
 - a. Complies with requirements of ASTM C 587 Standard Specification for Gypsum Veneer Plaster

2.6 GYPSUM PLASTER FINISH:

- A. Basis of Design: White Kote
 - 1. Physical Characteristics
 - a. Complies with requirements of ASTM C 587 Standard Specification for Gypsum Veneer Plaster
 - b. Requires high-strength Gypsum Base Coat over sanded or wood-fibered Gypsum Base Coats.
 - c. Finish: [Smooth]
 - d. Overall Thickness [1/16 inch Finish Coat]
- B. Basis of Design: Fenestra Old World Finish
 - 1. Physical Characteristics
 - a. Complies with requirements of ASTM C 587 Standard Specification for Gypsum Veneer Plaster
 - b. Finish: [Smooth]
 - c. Overall Thickness [1/16 to 1/8 inch Finish Coat]

PART III - EXECUTION

- 3.1 INSTALLATION: GYPSUM BASE COAT:
 - A. Install in accordance with manufacturer recommendations and in accordance with ASTM C 844 Specification for Application of Gypsum Base to Receive Veneer Plaster and Western Blended Products installation instructions.
- 3.2 INSTALLATION: GYPSUM FINISH COAT:
 - A. Install in accordance with manufacturer recommendations and in accordance with ASTM C 843 Specification for Application of Gypsum Veneer Plaster and Western Blended Products installation instructions.

August 21st, 2023.

WBP Specifications